

Frequency Stability in Modern Power Network from Complex Network Viewpoint

Hai-Peng Ren^a, Yuan Gao^a, Long Huo^a, Ji-hong Song^a, Celso Grebogi^{a,b},

^a*Shaanxi Key Laboratory of Complex System Control and Intelligent Information Processing,
Xian University of Technology Xi'an, Shaanxi 710048, China*

^b*Institute for Complex Systems and Mathematical Biology, Kings College, University of
Aberdeen, Aberdeen AB24 3UE, UK*

Abstract

Grid-connected operation of Renewable Energy and Storage (RES) nodes make the dynamics of modern power grid to be more complex. A model of power grid, considering RES nodes, is being proposed to address frequency synchronization and stability analysis. First, a unified dynamical model of four different types of nodes are established according to the swing equation, including the RES nodes with power-frequency droop inverter controllers. The storage nodes have charging and discharging states. We provide a sufficient condition for the existence and stability of frequency synchronized solution via the linear time-varying consensus protocol of multi-agent system. The results are validated by Western System Coordinating Council and the Shaanxi North Power Grid model.

Keywords:

renewable energy and storage, multi-agent system, frequency synchronization, stability, consensus protocol

1. Introduction

To solve the problem of energy consumption and carbon dioxide emission caused by the traditional fossil energy generation, the proportion of renewable energy generation is being increased in power grids. Grid-connected operation of intermittent energy, like solar energy or wind energy, leads to fluctuations in energy supplying and demanding, in spite of energy storage systems reduce such fluctuations. The modern power grid, therefore, is a time-varying, nonlinear coupled

Email address: renhaipeng@xaut.edu.cn (Hai-Peng Ren)

network, heterogeneously composed of Renewable Energy and Storage (RES) nodes and the conventional generation nodes^[1]. Therefore the traditional frequency synchronization methods are difficult to apply. The synchronization concept can be traced back to 1665, when C. Huygens found that coupled pendula would synchronously swing. The Kuramoto model, proposed by biologist Winfree and Kuramoto, has made much contribution to the synchronization research. A review [2] summarized a series of research results about the Kuramoto oscillators, including the stability analysis. Kuramoto model with a bimodal parameter distribution was proposed to describe the synchronous oscillation of the generator and load in [3]. However, there were the following shortcomings: 1) Lack of theoretical proofs about the stability and convergence of the frequency synchronization point; 2) The coupling weights of each edge and damping constant of each node is unnecessarily assumed to be equal; 3) The analysis complexity increases with the presence of higher order derivatives; 4) The model does not take RES nodes into account. The non-uniform Kuramoto model and the multi-agent consensus protocol were used to derive the sufficient condition for the frequency synchronization of power grid in [4]. However, the frequency stability analysis of power grid in [4] only considered the network connectivity and the initial phase of the nodes, without taking into account the effect of the Laplacian matrix on the stability. The critical coupling strength for frequency synchronization in power grid was obtained in [5] and [6] in 2012 by assuming that the coupling weights of each edge and the damping constant of each node are equal and did not consider the RES nodes as well^{[5][6]}, which was not agreeable with practical grids. The output of the generation nodes were controlled cooperatively according to the information exchanged with the ambient agent and the multi-agent consensus protocol, in order to guarantee the frequency stability of the grid^[7]. This article considered the dynamics of renewable energy equipped with droop controller, but did not consider the storage nodes with different working states. A necessary and sufficient condition for the existence of frequency synchronization solution in micro-grid with droop-controlled inverters were derived in [8]. However, all loads were assumed to be constant power loads in [8]. The methods of analyzing power grid frequency synchronization are mainly divided into two approaches: the grid topology and the grid dynamics. From the grid topology approach, the synchronous ability of the various grid sizes and the evolution patterns are primarily compared and analyzed using numerical experiments and statistical physics methods^{[9][10]}, which demonstrates the static characteristics in an analytical way, but cannot reflect the dynamical behavior of the power grid. From the grid dynamics approach, the relationship between dynamical behavior and the network parameters of the power

grid, and the grid frequency synchronization conditions are obtained in an analytical way^[3].

In this paper, to analyze frequency stability from the dynamics approach, we establish an unified dynamical model for the power grid including RES nodes, which simplifies the analysis complexity about the power grid frequency synchronization. We show that the frequency stability of power grid is influenced not only by the network connectivity and the initial phase of the nodes, but also by the time-varying Laplacian matrix of the power grid. Reference [4] gives the condition for the existence of frequency synchronized solution, but the result cannot guarantee the stability of the synchronized solution. A supplementary condition is given in this paper to decide whether the synchronized solution is stable by estimating the eigenvalues of the time-varying Laplacian matrix. Thereby, we derive the sufficient conditions for frequency synchronization and its stability in power grids that contains RES nodes. Finally, the conditions are verified by the Western System Coordinating Council model and the Shaanxi North Power Grid.

The remainder of this paper is organized as follows: in Section 2, some relevant preliminaries and notations are introduced. In Section 3, the uniform mathematical power grid model for four different types of nodes are given. In Section 4, the sufficient condition for frequency synchronization and stability of power grids are derived. The simulation results of both the Western System Coordinating Council and the Shaanxi North Power Grid are given in Section 5. Finally, some conclusions are drawn in Section 6.

2. Preliminaries and notation

2.1. The set of phase differences and positive invariance

From graphics geometry theory, $S^1 = (-\pi, +\pi]$ denotes the unit circle and the n -torus $T^n = S^1 \times S^2 \dots \times S^n$ is the Cartesian product of n unit circles. For $\gamma \in [0, \pi]$, let $\Delta(\gamma) \subset T^n$ be a set of angle arrays $(\theta_1, \theta_2, \dots, \theta_n) \in T^n$, so that there exists an arc of length γ containing all $\theta_1, \theta_2, \dots, \theta_n$ in its interior, which denotes the distance between two arbitrary angles in the phase arrays. Thus, an array of angles $\theta \in \Delta(\gamma)$ satisfies $\max_{i,j \in \{1,2,\dots,n\}} |\theta_i - \theta_j| \leq \gamma$, i.e., at each time t there exists an arc of length γ containing all angles $\theta_i(t)$; the set of phase differences $\Delta(\gamma)$ is positively invariant if it is no longer increasing. ^[3]

2.2. Algebraic graph theory

An arbitrary complex network can be represented by the relevant weighted graph.^[11] A weighted directed graph is a triple set $G = (v, \varepsilon, A)$, where $v =$

$\{1, 2, \dots, n\}$ is the set of nodes, $\varepsilon = \{(i, j) | i, j \in v\}$ is the set of directed edges, and $\mathbf{A} \in R^{n \times n}$ is the adjacent matrix, \mathbf{A} satisfies $a_{ij} > 0$ for each directed edge $\{i, j\} \in \varepsilon$ and otherwise $a_{ij} = 0$. a_{ij} is the coupling strength between node i and j . Degree matrix $\mathbf{D}_e \in R^{v \times v}$ is a diagonal matrix whose main diagonal entries are $\sum_{j=1}^n a_{ij}$. The node-edge incidence matrix $\mathbf{B} \in R^{v \times \varepsilon}$ is defined component-wise as $B_{kl} = 1$ if node k is the sink node of edge l and as $B_{kl} = -1$ if node k is the source node of edge l , with all other elements being zeros. Then the Laplacian matrix is given by $\mathbf{L} = \mathbf{D}_e - \mathbf{A}$, and is positive semidefinite with eigenvalues satisfying $0 = \lambda_1 < \lambda_2 < \dots < \lambda_{|v|}$, if $a_{ij} > 0$.^[12]

2.3. Linear time-varying consensus protocol of multi-agent system

Lemma 1. ^[13] Consider n nodes multi-agent system defined on a graph $G = (v, \varepsilon, \mathbf{A})$, x_i is the state variable of agent i , $(A_{kl}) = \alpha_{kl}$ is the coupling strength, which describes the interaction between agents, assume that each node satisfies the following equation,

$$\dot{x}_k(t) = \sum_{l=1, l \neq k}^n a_{kl}(t)(x_l(t) - x_k(t)), \quad (1)$$

which is given by

$$\dot{\mathbf{x}} = \mathbf{A}(t)\mathbf{x}. \quad (2)$$

Assume that all but one of the eigenvalues of the system matrix \mathbf{A} have strictly negative real part, the only exception is the trivial eigenvalues at zero, if and only if the associated digraph has (at least) one node from which all other nodes may be reached, then all the system state variables stably converge to a common value.

According to Lemma 1, we learn that, with the network connectivity varying, the eigenvalues of $\mathbf{A}(t)$ are also time-varying. When any, but zero eigenvalues of the system matrix \mathbf{A} , do not have strictly negative real part, or the globally reached node does not exist, then the equilibria states of Eq. (2) are no longer stable.

3. Mathematical model of different nodes in a power grid

3.1. The dynamical model of the generator

The dynamical model of the generator is given as follows

$$D_i \dot{\theta}_i = P_{mi} - \left(E_i^2 G_{ii} + \sum_{j=1}^n E_i E_j Y_{ij} \sin(\theta_i - \theta_j + \varphi_{ij}) \right), \quad (3)$$

where, in terms of node i , D_i and M_i are the damping and inertia constants, respectively, θ_i of node i is the angle of the shaft in radians with respect to a synchronously rotating reference, φ_{ij} is the phase shifts caused by transfer conductance, and E_i is the voltage magnitude of the synchronous machine. Y_{ij} is the admittance of transmission line between node i and node j , and G_{ii} is the self-conductance of node i . More details about the model parameters and derivation of Eq. (3) could be found in Appendix A.

3.2. The dynamical node of the load

Similar to the generator, the dynamics of the load is given as follows

$$M_i \ddot{\theta}_i = -P_{Li} - D_i \dot{\theta}_i - \left(E_i^2 G_{ii} + \sum_{j=1}^n E_i E_j \sin(\theta_i - \theta_j) \right). \quad (4)$$

Note that, the main difference between (4) and (A. 29) in Appendix A is the mechanical power. Since the load node is the energy consumption node, P_{Li} represents the active power that the load node consumes.

Similarly, when we investigate frequency synchronization, the inertia term can be omitted due to the fact that it only affects the convergence time of synchronization, thus dynamic models of the load nodes can be rewritten as

$$D_i \dot{\theta}_i = -P_{Li} - \left(E_i^2 G_{ii} + \sum_{j=1}^n E_i E_j \sin(\theta_i - \theta_j) \right). \quad (5)$$

3.3. Model of RES nodes based on droop control

For grid-connected RES nodes, it is very necessary to convert the DC or the non-industrial frequency AC power to the industrial frequency AC power by means of inverters. Power grid typically contains a bank of RES nodes equipped with power-frequency droop inverter controllers operated in parallel. Therefore, we establish the dynamics of RES nodes based on the droop control.

Droop control is a basic way of grid connected converters control, and is widely applied in the RES batteries converter technique^[15]. The frequency droop control formula is

$$f_i = f_{0i} - n_{p_i} P_i, \quad (6)$$

where the parameter $n_{p_i} = X_i/2\pi E_i E$ is referred to as the droop coefficient, E_i is the output voltage of inverter connected to the RES nodes, E is the voltage of DC bus, jX_i is the line impedance between inverter and bus, f_{0i} is the output frequency

of the unload inverter, and P_i is the output active power of the RES node. Proofs about droop control can be found in Appendix B. For simplicity, let $D_i = 1/n_{p_i}$, Eq. (6) is rewritten as

$$D_i f_i = D_i f_{0_i} - P_i. \quad (7)$$

In addition, we denote f_i by θ_i , the nominal power $D_i f_{0_i}$ by P_{di} , and the output power P_i as is done in (A. 26) in Appendix A. Then Eq. (7) is rewritten as

$$D_i \dot{\theta}_i = P_{di} - \left(E_i^2 G_{ii} + \sum_{j=1}^n E_i E_j \sin(\theta_i - \theta_j) \right). \quad (8)$$

Equation (8) is the model of RES nodes for discharging state.

The storage node works not only in discharge state, but also in charge state that can be treated as a load node, Thus, its model can be described by (5).

4. Frequency synchronization and stability analysis of a power grid based on complex network theory

We denote $G = (v, \varepsilon, \mathbf{A})$ as the topology of a power grid, where v is the set of nodes, ε is the set of transmission lines and \mathbf{A} is the adjacency matrix. The power grid includes n nodes and m transmission lines denoted as $|v| = n$, $|\varepsilon| = m$. Then all the nodes can be denoted as $\{v_G, v_L, v_D\}$, where v_G represents the set of the generator nodes, v_L represents the set of the load nodes, and v_D represents the set of the RES nodes.

In order to describe the various types of grid nodes using a uniform matrix form, we make the following transformation

$$\begin{aligned} P_{mi}^* &= P_{mi} - E_i^2 G_{ii}, i \in v_G, \\ P_{Li}^* &= -P_{Li} - E_i^2 G_{ii}, i \in v_L, \\ P_{Di}^* &= \pm P_{Di} - E_i^2 G_{ii}, i \in v_D, \end{aligned} \quad (9)$$

Then Eqs. (3), (5) and (8) can be written as

$$\begin{aligned} D_i \dot{\theta}_i &= P_{mi}^* - \sum_{j=1}^n E_i E_j |Y_{ij}| \sin(\theta_i - \theta_j), i \in v_G, \\ D_i \dot{\theta}_i &= P_{Li}^* - \sum_{j=1}^n E_i E_j |Y_{ij}| \sin(\theta_i - \theta_j), i \in v_L, \\ D_i \dot{\theta}_i &= P_{Di}^* - \sum_{j=1}^n E_i E_j |Y_{ij}| \sin(\theta_i - \theta_j), i \in v_D, \end{aligned} \quad (10)$$

Define

$$a_{ij} \triangleq E_i E_j |Y_{ij}|, \{i, j\} \in \mathcal{E}, \quad (11)$$

so we can rewrite the model in Eq. (10) in the following form

$$D_i \dot{\theta}_i = P_i^* - \sum_{j=1}^n a_{ij} \sin(\theta_i - \theta_j), i \in \mathcal{V}, \quad (12)$$

The above equation is described by using the following Laplacian matrix notation,

$$\mathbf{D}\dot{\theta} = \mathbf{P}^* - \mathbf{B}\mathbf{W} \sin(\mathbf{B}^T \theta), \quad (13)$$

where $\theta = [\theta_1, \dots, \theta_n]^T$, $\mathbf{D} = [D_1, \dots, D_n]^T$, $\mathbf{P}^* = [P_{m1}^*, \dots, P_{|V_G|}^*, P_{L1}^*, \dots, P_{|V_L|}^*, P_{D1}^*, \dots, P_{|V_D|}^*]^T$, \mathbf{B} and \mathbf{W} are the incidence matrix and weighted matrix, respectively.

To achieve a stable frequency synchronization solution in a power grid, firstly, it is necessary for the synchronization solution of Eq. (13) to exist, and secondly, the synchronization solution needs to guarantee to be stable.

A solution θ of Eq. (12) is said to be synchronized if $\dot{\theta}_i = \dot{\theta}_j$ for each node, so the frequency difference between two arbitrary nodes can be represented as follows

$$\dot{\theta}_i - \dot{\theta}_j = \frac{P_i^*}{D_i} - \frac{P_j^*}{D_j} - \sum_{k=1}^n \left(\frac{a_{ik}}{D_i} \sin(\theta_i - \theta_k) - \frac{a_{jk}}{D_j} \sin(\theta_j - \theta_k) \right), i, j \in \mathcal{V}. \quad (14)$$

To achieve frequency synchronization in power grid, the coupling strength between nodes i and j has to dominate the networks non-uniformity as shown in Eq. (15)

$$\frac{P_i^*}{D_i} - \frac{P_j^*}{D_j} < \sum_{k=1}^n \left(\frac{a_{ik}}{D_i} \sin(\theta_i - \theta_k) - \frac{a_{jk}}{D_j} \sin(\theta_j - \theta_k) \right), i, j \in \mathcal{V}. \quad (15)$$

By a scale transformation of inequalities (15), we get

$$\Gamma_{\min} \sin(\gamma) \geq \Gamma_{critical}, \quad (16)$$

where $\Gamma_{\min} = n \min_{i \neq j} \left\{ \frac{a_{ij}}{D_i} \right\}$, $\Gamma_{critical} = \max_{i \neq j} \left| \frac{P_i^*}{D_i} - \frac{P_j^*}{D_j} \right|$. There exists the frequency synchronized solution if the inequalities in Eq. (16) is satisfied.

The synchronization frequency can be obtained by summing all the rows of the matrix equation, Eq. (13), such that

$$\sum_{i=1}^n D_i \dot{\theta}_i = \sum_{i=1}^n P_i^* + \sum_{i=1}^n \sum_{j=1}^n a_{ij} \sin(\theta_i - \theta_j). \quad (17)$$

Assuming that there is the synchronization frequency ω_{sync} , the non-symmetric property of the sine function implies that the last term $\sum_{i=1}^n \sum_{j=1}^n a_{ij} \sin(\theta_i - \theta_j)$ is zero,

$$\text{then, } \omega_{sync} = \sum_{i=1}^n P_i^* \bigg/ \sum_{i=1}^n D_i.$$

After obtaining the synchronization solution, we need to analyze the stability of this solution. To prove the stability of the synchronized solution of Eq. (13), we consider the derivative of Eq. (12)

$$\ddot{\theta}_i = - \sum_{j=1}^n \frac{a_{ij}}{D_i} \cos(\theta_i - \theta_j) (\dot{\theta}_i - \dot{\theta}_j) \quad (18)$$

By defining $\alpha_{ij}^* = \frac{a_{ij}}{D_i} \cos(\theta_i - \theta_j)$, we rewrite Eq. (18) as

$$\ddot{\theta}_i = - \sum_{j=1}^n \alpha_{ij}^* (\dot{\theta}_i - \dot{\theta}_j) \quad (19)$$

The Laplacian matrix form of Eq. (19) is

$$\ddot{\theta} = -\mathbf{L}(t) \dot{\theta}, \quad (20)$$

where $\mathbf{L}(t) = \text{diag}\left(\sum_{j=1}^n \alpha_{ij}^*\right) - \{\alpha_{ij}^*\}$ is the Laplacian matrix, $\text{diag}\left(\sum_{j=1}^n \alpha_{ij}^*\right)$ represents a diagonal matrix whose main diagonal entries are $\sum_{j=1}^n \alpha_{ij}^*$, and $\{\alpha_{ij}^*\}$ represents a matrix with all entries being α_{ij}^* .

Obviously the form of Eq. (20) is similar to the form of the consensus protocol of the linear time invariant multi-agent system shown in Eq.(2). So we use Lemma 1 to analyze the stability of the frequency synchronization solution of a power grid.

Theorem 1. *Consider the power system (13), if $\theta(0) \in \Delta(\gamma)$, $\gamma \in [\gamma_{\min}, \pi/2]$, then there exists the synchronization frequency, where $\gamma_{\min} = \arcsin(\Gamma_{critical}/\Gamma_{\min})$. Furthermore, assuming that the network is globally reachable for all time and that all but one of the eigenvalues of the time-varying Laplacian matrix $-\mathbf{L}(t)$ have strictly negative real part, the only exception is the trivial eigenvalue at zero, if $\Delta(\gamma)$ is positively invariant, and the synchronization frequency is stable, then the frequency $\dot{\theta}_i(t)$ exponentially converges to the following common value: $\dot{\theta}_{\infty} =$*

$$\omega_{sync} = \sum_{i=1}^n P_i^* \bigg/ \sum_{i=1}^n D_i.$$

Proof: Note that

$$\gamma_{\min} = \arcsin\left(\frac{\Gamma_{critical}}{\Gamma_{\min}}\right). \quad (21)$$

Then,

$$\sin(\gamma_{\min}) = \frac{\Gamma_{critical}}{\Gamma_{\min}}. \quad (22)$$

Since for $\gamma \in [\gamma_{\min}, \pi/2]$, $\sin(\gamma)$ is strictly monotonously increasing on the interval $[0, \pi/2)$, then

$$\sin(\gamma) \geq \sin(\gamma_{\min}) = \frac{\Gamma_{critical}}{\Gamma_{\min}} \quad (23)$$

Due to $\Gamma_{\min} > \Gamma_{critical} > 0$, Eq. (16) holds from the fact that it can be derived by multiplying both sides of Eq. (23) by Γ_{\min} , consequently, there exists a synchronization frequency.

If all but one of the eigenvalues of the time-varying Laplacian matrix $-\mathbf{L}(t)$ of Eq. (20) have strictly negative real part, and the only exception is the trivial eigenvalues at zero, we have

$$-\mathbf{L}(t) = \begin{cases} -\sum_{j=1, j \neq i}^n \frac{a_{ij}}{D_i} \cos(\theta_i - \theta_j), & i = j \\ \frac{a_{ij}}{D_i} \cos(\theta_i - \theta_j), & i \neq j. \end{cases} \quad (24)$$

Therefore, $-\mathbf{L}(t)$ must be a Metzler matrix with row sum being zero (i.e., $-\mathbf{L}(t)$ is the matrix whose all main diagonal elements are negative and all off-diagonal elements are non-negative). According to Eq. (21), for $t > 0$, the following inequalities holds

$$\begin{cases} -\sum_{j=1, j \neq i}^n \frac{a_{ij}}{D_i} \cos(\theta_i - \theta_j) \leq 0 \\ \frac{a_{ij}}{D_i} \cos(\theta_i - \theta_j) \geq 0. \end{cases} \quad (25)$$

Because of $\frac{a_{ij}}{D_i} \geq 0, \forall i, j$, then the term $\cos(\theta_i - \theta_j) \geq 0, \forall i, j$ is true, that is $\gamma \in [\gamma_{\min}, \pi/2], |\theta_i - \theta_j| \leq \gamma$ for $t > 0$, so the set $\Delta(\gamma)$ is positively invariant, and the synchronization frequency is stable.

The conditions for the existence of synchronization solution given in [3] is described as follows: $\gamma \in [\gamma_{\min}, \pi/2], \gamma_{\min} = \arcsin(\Gamma_{critical}/\Gamma_{\min})$, then the set $\Delta(\gamma)$

is positively invariant. However, Theorem 1 in this work shows that, when the conditions given in [3] are satisfied, the existence of synchronization solution of the system can be proved, but the stability of this solution cannot be guaranteed. In this paper, assuming that the network is globally reachable for all time and that all but one of the eigenvalues of the time-varying Laplacian matrix $-\mathbf{L}(t)$ have strictly negative real part, the only exception is the trivial eigenvalues at zero; therefore, the set $\Delta(\gamma)$ is positively invariant, and the synchronization frequency is stable. Our Theorem in this paper gives supplementary information for the stability of the the frequency synchronization solution. The following simulation examples validate the applicability of this Theorem.

5. Model simulation and analysis




Figure 1. The grid topology of the Western System Coordinating Council

The grid topology of the Western System Coordinating Council (WSCC 9-BUS)^[14] is shown in Fig. 1, where buses 1, 2 and 3 connected to generators is treated as generator nodes, buses 5, 6 and 8 connected to loads can be viewed as load nodes, buses 4, 7 and 9 are transformer buses, and can be treated as single paths. We thus obtain a 6-node network model. Additionally, we assume that there are three generator nodes, where node 1 is the classical generator node, node 2 is the renewable energy node, and node 3 is the storage node that operates in discharging state. The nodes parameters and lines parameters of the Western System Coordinating Council in the simulations are given in Tables 1 and 2. From Table 2, the branch resistance value is an order of magnitude smaller than the branch reactance value.

Table 1: The nodes parameters of the Western System Coordinating Council

Node Number	Node Voltage		Node Power	Node Damping
	$U(p.u.)$	$\delta(^{\circ})$	$P(p.u.)$	$D(p.u.)$
1 (Bus 1)	1.0400	0	16.30	0.2
2 (Bus 2)	1.0250	9.2800	8.00	0.1
3 (Bus 3)	1.0250	4.6648	0.85	0.1
4 (Bus 4)	0.9956	-3.9888	-1.00	0.1
5 (Bus 5)	1.0127	-3.6874	-0.90	0.1
6 (Bus 6)	1.0159	0.7275	-0.80	0.1

Table 2: The line parameters of the Western System Coordinating Council

Source Node	Sink Node	Branch Resistance	Branch Reactance
1	4	0.0100	0.2034
1	5	0.0170	0.2104
2	4	0.0320	0.3433
2	6	0.0085	0.2543
3	5	0.0390	0.4099
3	6	0.0119	0.2708

We can calculate from the parameters to obtain: $\Gamma_{\min} = n \min_{i \neq j} \left\{ \frac{a_{ij}}{D_i} \right\} = 598.9573$, $\Gamma_{critical} = \max_{i \neq j} \left| \frac{P_i^*}{D_i} - \frac{P_j^*}{D_j} \right| = 91.5$, $\gamma_{\min} = \arcsin \left(\frac{\Gamma_{critical}}{\Gamma_{\min}} \right) = 8.7872^{\circ}$ and $\gamma = \max_{i \neq j} |\theta_i(0) - \theta_j(0)| = 13.269^{\circ}$. Since $\gamma \in (\gamma_{\min}, \pi/2)$, according to Theorem 1, there exists the frequency synchronized solution, since Laplace matrix $\mathbf{L}(t)$ is time-varying, its eigenvalues change as well, where $\alpha_{ij}^* = \frac{a_{ij}}{D_i} \cos(\theta_i - \theta_j)$. Figure 2 (b) illustrates that the largest eigenvalue of $-\mathbf{L}(t)$ is zero before 9 seconds, after 9 seconds, the maximum eigenvalue of the system is far greater than zero, which does not satisfy the stability condition given by Theorem 1. Figure 2 (c) illustrates the phase differences divergence. Therefore, although there exists a frequency synchronization solution, the solution is unstable. Thus the system does not obtain the stable synchronization frequency as shown in Figure 2 (a).

In Figure 3 the simulation parameters are changed. The damping vector is $\mathbf{D} = [2, 1, 1, 1, 1, 1]^T$. The injection power $\mathbf{P} = [1.63, 0.8, 0.85, -1, -0.9, -0.8]^T$. The simulation results are shown in Figure 3. In this case we have $\Gamma_{\min} = n \min_{i \neq j} \left\{ \frac{a_{ij}}{D_i} \right\} = 59.986$, $\Gamma_{critical} = \max_{i \neq j} \left| \frac{P_i^*}{D_i} - \frac{P_j^*}{D_j} \right| = 1.85$, $\gamma_{\min} = \arcsin \left(\frac{\Gamma_{critical}}{\Gamma_{\min}} \right) = 1.77^{\circ}$ and γ is the







Figure 2. Subplots (a), (b), (c) illustrate the nodes frequency variation, the largest eigenvalue of $-\mathbf{L}(t)$ and the node phase variation of the Western System Coordinating Council, respectively. Simulation results using $\mathbf{D} = [0.2, 0.1, 0.1, 0.1, 0.1, 0.1]^T$ and $\mathbf{P} = [16.3, 8, 0.85, -1, -0.9, -0.8]^T$.

same as that in Figure 2.


For $\gamma \in (\gamma_{\min}, \pi/2)$, there exists a frequency synchronization solution. Moreover, the largest eigenvalue of $-\mathbf{L}(t)$ is always zero and others are smaller than zero, which satisfies the stability condition given by Theorem 1, the set $\Delta(\gamma)$ is positively invariant. Fig. 3 (c) illustrates that the phase difference between arbitrary two nodes converges, that is, the synchronization frequency is stable for these parameters. Therefore, the solutions of the system exponentially converge to



(a) The nodes frequency variation



(b) The largest eigenvalue of $-\mathbf{L}(t)$



(c) Node phase variation

Figure 3. Subplots (a), (b), (c) illustrate the nodes frequency variation, the largest eigenvalue of $-\mathbf{L}(t)$ and the node phase variation of Western System Coordinating Council, respectively. Simulation results using $\mathbf{D} = [2, 1, 1, 1, 1, 1]^T$ and $\mathbf{P} = [1.63, 0.8, 0.85, -1, -0.9, -0.8]^T$.

stable synchronization frequency in Figure 3 (a). In another words, the frequency of all nodes converge to the stable value $\dot{\theta}_\infty = \sum_{i=1}^n P_i^* \bigg/ \sum_{i=1}^n D_i$.

The North Local Power Grid of Shannxi Province with 58 generator nodes and 57 load nodes is used to verify Theorem 1 in this paper. The nodes data and branch data can be found in Appendix C, where the node type 1 (node type 2) means the node is a generator (a load). We can calculate from the parameters in Appendix C

and obtain $\Gamma_{\min} = n \min_{i \neq j} \left\{ \frac{a_{ij}}{D_i} \right\} = 11.0764$, $\Gamma_{critical} = \max_{i \neq j} \left| \frac{P_i^*}{D_i} - \frac{P_j^*}{D_j} \right| = 4.3505$, $\gamma_{\min} = \arcsin \left(\frac{\Gamma_{critical}}{\Gamma_{\min}} \right) = 23.1246^\circ$ and $\gamma = \max_{i \neq j} |\theta_i(0) - \theta_j(0)| = 60.2112^\circ$. Obviously, for $\gamma \in (\gamma_{\min}, \pi/2)$, there exists a frequency synchronization solution. Moreover, as shown in Figure 4 (b), the largest eigenvalue of $-\mathbf{L}(t)$ is always zero and other eigenvalues are smaller than zero, which satisfies the stability condition given in Theorem 1, the set $\Delta(\gamma)$ is positively invariant. Figure 4 (c) illustrates that the phase difference between arbitrary two nodes converges, that is the synchronization frequency is stable under these parameters. Therefore, the solutions of the system exponentially converge to stable synchronization frequency as shown in Figure 4 (a). In Figure 5, the simulation parameters are changed.




Figure 4. Subplots (a), (b), (c) illustrate the nodes frequency variation, the largest eigenvalue of $-\mathbf{L}(t)$ and the node phase variation of the North Local Power Grid of Shannxi Province, respectively. Simulation results using the parameters in Appendix C


The damping of all nodes are the same as those in Appendix C, but the power of all the nodes are 5 times larger than those in Appendix C. In this case we have $\Gamma_{\min} = n \min_{i \neq j} \left\{ \frac{a_{ij}}{D_i} \right\} = 11.0764$, $\Gamma_{critical} = \max_{i \neq j} \left| \frac{P_i^*}{D_i} - \frac{P_j^*}{D_j} \right| = 8.8901$, $\gamma_{\min} = \arcsin \left(\frac{\Gamma_{critical}}{\Gamma_{\min}} \right) = 53.3825^\circ$ and $\gamma = \max_{i \neq j} |\theta_i(0) - \theta_j(0)| = 60.2112^\circ$. According to Theorem 1, there exists the frequency synchronization solution, since Laplace matrix $\mathbf{L}(t) = \text{diag} \left(\sum_{j=1}^n \alpha_{ij}^* \right) - \{\alpha_{ij}^*\}$ is time-varying, its eigenvalues change as well, where $\alpha_{ij}^* = \frac{a_{ij}}{D_i} \cos(\theta_i - \theta_j)$. Figure 5 (b) illustrates that the largest eigenvalue of $-\mathbf{L}(t)$ is zero before 4.8 seconds, after 4.8 seconds the maximum eigenvalue of the system is greater than zero, which does not satisfy the stability condition given in Theorem 1. As shown in Figure 5 (c), the phase differences are divergent. Therefore, although there does exist the frequency synchronization solution, the solution is unstable. Thus the system does not obtain the stable synchronization frequency as shown in Figure 5 (a).

6. Conclusions


The models of generator and load nodes, according to rotor dynamics of the generator and the RES nodes and equipped with power-frequency droop inverter controllers, are given in this paper, where the storage nodes have two operating states. We proved that the stability of synchronization solutions depends on the Laplacian matrix $-\mathbf{L}(t)$ given in Eq. (20), using the consensus protocol of the linear time-varying multi-agent system. If all but one of the eigenvalues of the time-varying Laplacian matrix $-\mathbf{L}(t)$ have strictly negative real part, and the only exception is the trivial eigenvalue at zero, then $\Delta(\gamma)$ is positively invariant and the synchronization solutions is stable. Simulation examples validate the applicability of this Theorem using the power grid of the Western System Coordinating Council and the North Local Power Grid of Shaanxi Province.

Acknowledgement


The work is supported in part by Key Program of Nature Science Fund of Shaanxi Province (2016ZDJC-01), IRT of Shaanxi Province (2013KCT-04).



(a) The nodes frequency variation



(b) The largest eigenvalue of $-\mathbf{L}(t)$



(c) Node phase variation

Figure 5. Subplots (a), (b), (c) illustrate the nodes frequency variation, the largest eigenvalue of $-\mathbf{L}(t)$ and node phase variation of the North Local Power Grid of Shannxi Province, respectively. Simulation results using the node power parameters which are 5 times larger than those in Appendix C

Reference

- [1] C.C. Chu, H.C. Iu, Complex networks theory for modern smart grid applications: a survey, *J. IEEE Journal on Emerging & Selected Topics in Circuits & Systems* 7(2) (2017) 177-191.
- [2] F.A. Rodrigues, T.K.D.M. Peron, P. Ji, J. Kurths, The Kuramoto model in complex networks, *J. Physics Reports* 610 (2016) 1-98.
- [3] G. Filatrella, A.H. Nielsen, N.F. Pedersen, Analysis of a power grid using a Kuramoto-like model, *J. European Physical Journal B* 61(4) (2008) 485-491.

- [4] F. Dörfler, F. Bullo, Synchronization and transient stability in power networks and non-uniform Kuramoto oscillators, *J. SIAM Journal on Control & Optimization* 50(3) (2012) 1616-1642.
- [5] R. Carareto, M.S. Baptista, C. Grebogi, Natural synchronization in power-grids with anti-correlated units, *J. Communications in Nonlinear Science & Numerical Simulation* 18(4) (2012) 1035-1046.
- [6] S. Lozano, L. Buzna, A.D. Guilera, Role of network topology in the synchronization of power systems, *J. The European Physical Journal B* 231(85) (2012) 231-238.
- [7] L.Y. Lu, C.C. Chu, Consensus-based secondary frequency and voltage droop control of virtual synchronous generators for isolated AC micro-grids, *J. IEEE Journal on Emerging & Selected Topics in Circuits & Systems* 5(3) (2015) 443-455.
- [8] J.W.S. Porco, F. Dörfler, F. Bullo, Synchronization and power sharing for droop-controlled inverters in islanded microgrids, *J. Automatica* 49(9) (2013) 2603-2611.
- [9] J. Wang, Y.H. Liu, Y.Jiao, H.Y. Hu, Cascading dynamics in congested complex networks, *J. The European Physical Journal B* 67(1) (2009) 95-100.
- [10] L.X. Yang, J. Jiang, Impacts of link addition and removal on synchronization of an elementary power network, *J. Physica A* 479 (2017) 99-107.
- [11] C. Godsil, Algebraic graph theory, *J. Springer*, 2001.
- [12] F. Dörfler, F. Bullo, Kron, Reduction of graphs with applications to electrical networks, *J. IEEE Transactions on Circuits & Systems I: Regular Papers* 60(1) (2013) 150-163.
- [13] L. Moreau, Stability of continuous-time distributed consensus algorithms, *J. IEEE Conference on Decision and Control* 4 (2004) 3998-4003.
- [14] P.M. Anderson, A.A. Fouad, Power system control and stability, *J. Wiley*, 2003.
- [15] X.F. Sun, Y.C. Hao, Q.F. Wu, X.Q. Guo, B.C.Wang, A Multifunctional and wireless droop control for distributed energy storage units in islanded AC

microgrid applications, J. IEEE Transactions on Power Electronics 32(1) (2017) 736-751.

Appendix A.

The motion equation of the generator rotor is governed by

$$J\ddot{\delta} = T_a, \quad (\text{A.1})$$

where δ is the mechanical angle of the shaft in radians with respect to a fixed reference, J is the moment of inertia of the rotor in $kg.m^2$, and T_a is the sum torque in Newton meters.

$$\begin{aligned} J\ddot{\delta} &= T_m - T_L \\ J\ddot{\delta} &= T_m - (T_e + T_d) \end{aligned} \quad (\text{A.2})$$

The angular reference is chosen with respect to a synchronously rotating reference frame, then

$$\delta = \omega_R t + \theta_m, \quad (\text{A.3})$$

$$\begin{aligned} \dot{\delta} &= \omega_R + \dot{\theta}_m = \omega_R + \omega_m \\ \text{and } \ddot{\delta} &= \ddot{\theta}_m = \dot{\omega}_m, \end{aligned} \quad (\text{A.4})$$

where θ_m is the mechanical angle of the shaft in radians with respect to a synchronously rotating reference frame, $\dot{\theta}_m$ is the angular velocity of the shaft, ω_R is synchronously rotating angular velocity.

Another form of (A.2) is obtained by multiplying its both sides with ω_m , as shown by Eq. (A.5)

$$\begin{aligned} J\omega_m\ddot{\theta}_m &= P_m - P_L \\ M\ddot{\theta}_m &= P_m - P_L, \end{aligned} \quad (\text{A.5})$$

where $P_m = T_m\omega_m$ is the mechanical power, $P_L = T_L\omega_m$ is the load power. The quantity $J\omega_m$ is called the inertia constant and is denoted by M , it is related to kinetic energy of the rotating masses W_k , where $W_k = \frac{1}{2}J\omega_m^2$. Then M can be calculated as follows

$$M = J\omega_m = \frac{2W_k}{\omega_m}. \quad (\text{A.6})$$

The electrical angle θ_e can be used to denote all of the equations above,

$$\theta = \theta_e = \frac{p}{2}\theta_m, \quad (\text{A.7})$$

where p is the number of pole pairs of the (generator) motor, which is calculated as follows

$$p = \frac{120f_R}{n_R}, \quad (\text{A.8})$$

where, n_R is the rated shaft speed in *rad/min*, f_R is the synchronously rotating frequency in *Hz*.

The equation (A.1) can be equivalently written as

$$\left(\frac{2J}{p}\right)\ddot{\theta} = \left(\frac{2J}{p}\right)\dot{\omega} = T_a (\text{N} \cdot \text{m}). \quad (\text{A.9})$$

Now, normalize Eq. (A.9) by dividing both sides by a constant equal to the rated torque at the rated speed

$$T_B = \frac{S_{B3}}{\omega_{mR}} = \frac{60S_{B3}}{2\pi n_R}, \quad (\text{A.10})$$

where S_{B3} is the rated three-phase power (VA), $\omega_{mR} = 2\pi n_R/60$ is the rated angular velocity of the shaft.

According to Eqs (A.8)-(A.10), we have

$$\left(\frac{J\pi^2 n_R^2}{900\omega_R S_{B3}}\right)\dot{\omega} = \frac{T_a}{T_B} = T_{au} \text{ p.u.}, \quad (\text{A.11})$$

where $\frac{T_a}{T_B} = T_{au}$. The moment of inertia $J = \frac{746(WR^2)}{500g}$ can be obtained by using the method in [14], and $(WR^2)/g$ is the unit of J . Then, by the following transformation

$$\frac{746(WR^2)\pi^2 n_R^2}{550g \times 900\omega_R S_{B3}}\dot{\omega} = T_{au} \text{ p.u.} \quad (\text{A.12})$$

$$W_k = \frac{1}{2}J\omega_m^2 = \frac{1}{2} \times \frac{746(WR^2)}{550g} \times \frac{(2\pi n_R)^2}{3600} = \frac{746(WR^2)\pi^2 n_R^2}{550g \times 1800} \quad (\text{A.13})$$

$$H \triangleq \frac{W_k}{S_{B3}}, \quad (\text{A.14})$$

we have

$$\left(\frac{2W_k}{S_{B3}\omega_R}\right)\dot{\omega} = T_{au} \text{ p.u.} \quad (\text{A.15})$$

$$\left(\frac{2H}{\omega_R}\right)\dot{\omega} = T_{au} \text{ p.u.} \quad (\text{A.16})$$

For a classical model of the synchronous machine, recognizing that the angular speed is nearly constant, the accelerating power P_a in p.u. is nearly equal to the accelerating torque T_a ^[14], then the generator becomes

$$\left(\frac{2H}{\omega_R}\right)\dot{\omega} \cong P_a \text{ p.u.} \quad (\text{A.17})$$


In addition, the damping torque (damping power) includes both the mechanical and electrical damping, which is represented by $D\omega$, then (A.17) can be rewritten as

$$\left(\frac{2H}{\omega_R}\right)\dot{\omega} = P_m - P_e - P_d = P_m - P_e - D\omega \text{ pu}, \quad (\text{A.18})$$

where $P_d = D\omega$ is the damping power. The concrete formula of the electrical output power P_e of the generator is derived as follows. Consider a power system consisting of one machine connected to an infinite bus through a transmission line. A schematic representation of this case is shown in Figure A. 1 (a), E is the internal voltage of the synchronous machine, L is the equivalent inductance of the transmission line, and V is the voltage of the infinite bus, which is used as reference. The equivalent electrical circuit of the system is given in Figure A. 1 (b), $\mathbf{E} = E\angle\delta$ is the voltage vector of the synchronous machine and δ is the voltage phase, and $\mathbf{V} = V\angle 0$ is the voltage vector of the infinite bus, x'_d is the transient reactance of the machine, \bar{V}_t is the terminal voltage of the synchronous machine, which can be eliminated by using $Y - \Delta$ transformation, \bar{Z}_s is the equivalent shunt impedance at the machine terminal, and \bar{Z}_{TL} is the series impedance of the transmission line. Another equivalent circuit of Figure 1 (b) is given in Figure A. 1 (c) by a $Y - \Delta$ transformation.


Assumptions for deriving the model are the following: 1) The mechanical power input remains constant during the transient period. 2) Damping or asynchronous power is negligible. 3) The synchronous machine can be represented by a constant voltage source and its mechanical angle coincides with the electrical phase angle of the voltage. 4) If a local load is fed at the terminal voltage of the machine, it can be represented by a constant impedance to neutral point.

In Figure A. 1 (a) we define: Nodes 0, 1 and 2 are the reference nodes, the internal voltage node of the synchronous machine and the infinite bus node, respectively; \mathbf{y}_{10} , \mathbf{y}_{12} , \mathbf{y}_{20} are the three admittance elements, respectively, derived by using a $Y - \Delta$ transformation.



(a) A schematic representation of one machine connected to an infinite bus through a transmission line

(b) The equivalent electrical circuit of one machine connected to an infinite bus through a transmission line



(c) Another equivalent circuit of one machine connected to an infinite bus through a transmission line

Figure A1. One machine connected to an infinite bus through a transmission line

The symbols with an arrow in the following equations are the vector variables corresponding to the Figure A. 1 (c). For node 1, according to Kirchhoff's law, we obtain:

$$\mathbf{I}_1 = (\mathbf{E} - \mathbf{V})\mathbf{y}_{12} + \mathbf{E}\mathbf{y}_{10} = \mathbf{E}\mathbf{y}_{12} - \mathbf{V}\mathbf{y}_{12} + \mathbf{E}\mathbf{y}_{10} = \mathbf{E}(\mathbf{y}_{12} + \mathbf{y}_{10}) - \mathbf{V}\mathbf{y}_{12}. \quad (\text{A.19})$$

Define:

$$\begin{aligned} \mathbf{Y}_{11} &= Y_{11} \angle \theta_{11} = \mathbf{y}_{12} + \mathbf{y}_{10}, \theta_{11} = \arctan\left(\frac{\text{real}(Y_{11})}{\text{imag}(Y_{11})}\right) \\ \mathbf{Y}_{12} &= Y_{12} \angle \theta_{12} = -\mathbf{y}_{12}, \theta_{12} = \arctan\left(\frac{\text{real}(Y_{12})}{\text{imag}(Y_{12})}\right). \end{aligned} \quad (\text{A.20})$$

Then,

$$\mathbf{I}_1 = \mathbf{E}\mathbf{Y}_{11} + \mathbf{V}\mathbf{Y}_{12} = EY_{11}e^{j(\delta+\theta_{11})} + VY_{12}e^{j\theta_{12}}. \quad (\text{A.21})$$

So the power input P_e at node 1 is

$$P_e = \text{real}(\mathbf{EI}_1^*) \quad (\text{A.22})$$

$$\mathbf{EI}_1^* = Ee^{j\delta} (EY_{11}e^{-j(\delta+\theta_{11})} + VY_{12}e^{-j\theta_{12}}) = E^2Y_{11}e^{-j\theta_{11}} + EVY_{12}e^{-j(\theta_{12}-\delta)} \quad (\text{A.23})$$

$$P_e = \text{real}(\mathbf{EI}_1^*) = E^2Y_{11} \cos \theta_{11} + EVY_{12} \cos (\theta_{12} - \delta). \quad (\text{A.24})$$

When the voltage angle of the infinite bus is different from zero, we can also get the corresponding P_e , given as

$$P_e = \text{real}(\mathbf{EI}_1^*) = E^2Y_{11} \cos \theta_{11} + EVY_{12} \cos (\theta_{12} + \alpha - \delta). \quad (\text{A.25})$$

Now, we get the compact formula of the electrical output power of the generator as Eq. (A. 25). Define $\beta = \frac{\pi}{2} - \theta_{12}$ and $G_{11} \triangleq Y_{11} \cos \theta_{11}$, G_{11} is the self-conductance, then Eq.(A. 25) is written as

$$P_e = E^2G_{11} + EVY_{12} \sin (\delta - \alpha + \beta). \quad (\text{A.26})$$

Consequently, we can get the mathematical model of the generator node in the power system ^[14] as

$$\left(\frac{2H}{\omega_R} \right) \dot{\omega} = P_m - P_d - P_e = P_m - D\omega - E^2G_{11} - EVY_{12} \sin (\delta - \alpha + \beta). \quad (\text{A.27})$$

In nodes power grid, the dynamic models of the generator nodes can be written as

$$\left(\frac{2H_{mi}}{\omega_R} \right) \dot{\omega}_i = P_{mi} - D_i\omega_i - \left(E_i^2G_{ii} + \sum_{j=1}^n E_iE_jY_{ij} \sin(\delta_i - \delta_j + \varphi_{ij}) \right). \quad (\text{A.28})$$

It can be also expressed as

$$M_i\ddot{\theta}_i = P_{mi} - D_i\dot{\theta}_i - \left(E_i^2G_{ii} + \sum_{j=1}^n E_iE_jY_{ij} \sin(\theta_i - \theta_j + \varphi_{ij}) \right), \quad (\text{A.29})$$

where $M_i\ddot{\theta}_i$ is the inertial term. When frequency synchronization analysis of (A. 29) is carried out, the inertia term $M_i\ddot{\theta}_i$ can be omitted due to the fact that it only affects the convergence time to synchronize the state but not its existence ^[14]. In addition, the resistive component is much smaller than the inductive component

of the generators output impedance and the line impedance, then $\varphi_{ij} = 0$. In consequence, the dynamic models of the generator nodes is given by

$$D_i \dot{\theta}_i = P_{mi} - \left(E_i^2 G_{ii} + \sum_{j=1}^n E_i E_j Y_{ij} \sin(\theta_i - \theta_j + \varphi_{ij}) \right), \quad (\text{A.30})$$

where, in terms of node i , D_i and M_i are the damping and inertia constants, respectively, θ_i of node i is the angle of the shaft in radians with respect to a synchronously rotating reference, φ_{ij} is the phase shifts caused by transfer conductance, E_i is the voltage magnitude of the synchronous machine, Y_{ij} is the admittance of the transmission line between nodes i and j , and $G_{ii} \triangleq Y_{ii} \cos \theta_i$ is the self-conductance.

Appendix B.

The model for the droop controlled inverter connected RES node is the following.

Power grid typically contains a bank of RES nodes equipped with active power-frequency droop inverter controllers operating in parallel. For the convenience of analysis, using two inverters in parallel as an example, Figure A.2 is the equivalent circuit for two inverters operating in parallel, where E_1, E_2 are the input voltage and I_1, I_2 are the input current of inverter 1 and 2, respectively. R_i is the input impedance of inverter i , jX_i is the line impedance between inverter and bus, E is the voltage of load bus, I_0, Z_0 are the load current and load impedance, respectively, and δ_1, δ_2 are the voltage phase difference between inverter 1, 2 and the bus, respectively. We get the inverter output active power from Figure B. 1.




Figure B1. The equivalent circuit of two inverters operating in parallel

$$P_i = \frac{R_i E_i E \cos \delta_i - R_i E^2}{X_i^2 + R_i^2} + \frac{X_i E_i E}{X_i^2 + R_i^2} \sin \delta_i, i = 1, 2. \quad (\text{B.1})$$

Assume that the entire inverter system is inductive, the resistive portion of the inverter output impedance and line impedance is much smaller than the inductive portion, and assume that the two inverters output impedance are equal, i.e, $R_1 = R_2 \approx 0$, then Eq. (B. 1) can be equivalently transformed as

$$P_i = \frac{E_i E}{X_i} \sin \delta_i, i = 1, 2. \quad (\text{B.2})$$

Compared with the load impedance, inverter source output reactance is very small, so the output voltage phase angle difference δ_i is also very small. Then we have $\sin \delta_i \approx \delta_i$, therefore Eq. (B. 2) can equivalently be given by :

$$P_i = \frac{E_i E}{X_i} \delta_i, i = 1, 2. \quad (\text{B.3})$$

Additionally, in a practical inverter system, the variation range of output voltage amplitude is not large, which can be approximately viewed as a constant, then the output power of inverter system is only related to the phase angle difference δ_i

$$\Delta P_i = \frac{E_i E}{X_i} \Delta \delta_i, i = 1, 2. \quad (\text{B.4})$$

Since the phase control is achieved by adjusting the output frequency, the output frequency change of the inverter is $\Delta f_i = \frac{\Delta \omega_i}{2\pi} = \frac{\Delta \delta_i}{2\pi \Delta t}$, so we can change the inverter output phase by adjusting the output frequency, thereby, altering the active power output of the inverter.

Define

$$n_{p_i} = \frac{X_i}{2\pi E_i E}, \quad (\text{B.5})$$

where the parameter n_{p_i} is referred to as the droop coefficient, then the frequency droop control formula can be obtained

$$f_i = f_{0_i} - n_{p_i} P_i, \quad (\text{B.6})$$

where f_{0_i} is the output frequency of the inverter without load.

Appendix C.

Table C.3: The nodes parameters of the North Local Power Grid of Shannxi Province

Node Number	Node type	Node Voltage	Node phase	Node Power	Node Damping
		$U(p.u.)$	$\delta(^{\circ})$	$P(p.u.)$	$D(p.u.)$
1	1	0.9259	-1.3448	0.4950	3
2	2	0.9492	-11.7136	-0.3658	2
3	1	0.9679	-13.8526	1.0000	3
4	2	1.0012	3.1051	-6.3509	2
5	2	0.6971	-2.4949	-0.8509	2
6	1	0.9543	5.0374	2.7000	3
7	1	1.1242	-8.9266	2.0000	3
8	2	0.8933	19.0851	-3.8909	2
9	2	1.0934	1.2223	-0.9609	2
10	2	1.0350	10.4703	-0.2609	2
11	2	0.9971	-2.2692	-0.2209	2
12	2	1.0182	-1.6250	-0.7609	2
13	2	0.8435	6.9005	-0.1809	2
14	1	0.9915	5.5576	0.7500	3
15	2	1.1604	-11.2026	-0.6309	2
16	2	1.0098	-15.3269	-0.2009	2
17	2	1.0041	-10.9787	-0.2409	2
18	1	0.9266	-14.1577	2.7000	3
19	2	0.9969	0.5957	-0.2109	2
20	2	1.0232	-4.1125	-0.2259	2
21	2	1.0426	-3.6801	-0.4809	2
22	1	0.9627	-13.6096	1.0000	3

Node Number	Node type	Node Voltage	Node phase	Node Power	Node Damping
		$U(p.u.)$	$\delta(^{\circ})$	$P(p.u.)$	$D(p.u.)$
23	1	0.9764	7.7957	1.0000	3
24	1	1.2024	4.3941	1.0000	3
25	1	0.7742	-0.8962	0.3000	3
26	2	1.2229	10.2118	-0.2409	2
27	2	1.0338	-8.7398	-0.4009	2
28	2	1.1000	4.1470	-2.0609	2
29	1	0.8336	3.4844	0.0200	3
30	2	0.9410	3.4925	-0.9609	2
31	2	0.9722	-7.2925	-0.2609	2
32	1	1.0423	3.2684	0.7200	3
33	1	0.8330	-5.1488	0.5000	3
34	1	1.0472	-8.9645	1.0000	3
35	1	0.8787	-12.0327	2.0000	3
36	1	1.0066	10.3782	1.0000	3
37	1	1.0652	-8.4594	0.3000	3
38	1	1.0327	-1.7291	0.5000	3
39	2	1.1083	-12.0865	-0.2009	2
40	1	1.1006	-2.9713	0.7500	3
41	2	0.9349	-32.3204	-0.2609	2
42	2	1.0257	-10.8696	-0.2009	2
43	2	0.9056	-14.2644	-0.2609	2
44	2	0.8678	-10.1445	-0.3209	2
45	2	1.0925	-2.1327	-0.2809	2
46	1	1.0000	-3.2535	0.3000	3
47	1	0.9945	19.4440	0.1200	3
48	2	1.0911	-5.7177	-0.5609	2
49	2	1.0595	-2.5003	-0.1809	2
50	2	1.0350	-15.6932	-0.2009	2
51	2	1.1250	-4.7738	-0.3109	2
52	2	1.0930	-13.3798	-0.3609	2
53	2	1.0240	0.3030	-0.2609	2
54	2	0.9310	8.5309	-0.3409	2
55	2	0.9348	4.0425	-0.5609	2
56	2	1.1192	-7.0062	-0.1809	2
57	2	0.8388	-16.3054	-0.2109	2
58	2	0.9976	14.6001	-0.2209	2
59	2	0.8051	20.5004	-0.4609	2
60	2	1.1020	1.2050	-0.6609	2

Node Number	Node type	Node Voltage	Node phase	Node Power	Node Damping
		$U(p.u.)$	$\delta(^{\circ})$	$P(p.u.)$	$D(p.u.)$
61	1	1.0862	-9.8990	0.7400	3
62	1	1.0001	11.9777	0.7700	3
63	1	0.9929	-5.9266	0.4000	3
64	2	0.7514	-4.6981	-0.5609	2
65	2	1.0581	8.8638	-0.2009	2
66	1	0.7808	-13.8522	1.0000	3
67	2	0.7681	-19.5675	-0.2609	2
68	2	1.0080	4.2068	-0.6609	2
69	2	0.9052	4.0074	-0.4109	2
70	2	1.0411	0.9514	-0.2609	2
71	1	1.0677	4.9668	0.8000	3
72	1	1.0858	10.8224	0.3000	3
73	2	0.9309	9.7045	-0.3109	2
74	2	1.0449	-5.6857	-0.2209	2
75	2	1.0101	8.0997	-0.2209	2
76	1	1.0826	1.7325	0.6000	3
77	1	1.0536	-5.0554	0.2400	3
78	1	1.0898	-11.9331	0.5000	3
79	1	0.9868	6.4697	0.4500	3
80	1	0.9853	-3.5362	0.3000	3
81	2	1.1008	0.4643	-0.4009	2
82	2	0.7876	-7.9295	-0.4109	2
83	2	0.9495	-15.5051	-0.3609	2
84	1	0.8729	1.7159	0.5000	3
85	1	0.9617	-0.6214	0.5000	3
86	1	1.0649	11.9903	0.2400	3
87	1	1.0826	8.0170	0.5000	3
88	1	0.8985	10.5330	0.5000	3
89	1	0.9529	-7.4888	0.1200	3
90	1	1.0137	-9.3633	0.6000	3
91	1	0.9708	-12.6909	1.9000	3
92	1	1.0302	4.9798	0.4950	3
93	1	1.0400	27.8908	0.4950	3
94	1	0.9070	7.2757	1.2600	3
95	1	0.9823	-7.7306	0.0100	3
96	1	0.7868	8.3663	0.9500	3
97	1	1.1145	-11.2833	0.4950	3
98	2	0.9371	-14.2447	-2.0109	2

Node Number	Node type	Node Voltage	Node phase	Node Power	Node Damping
		$U(p.u.)$	$\delta(^{\circ})$	$P(p.u.)$	$D(p.u.)$
99	1	0.8796	7.1744	0.6000	3
100	1	0.9746	-7.7791	0.9900	3
101	1	0.8571	3.1599	0.4950	3
102	1	0.9979	14.0654	0.8000	3
103	1	0.9439	4.0112	1.0000	3
104	1	1.2178	9.2966	0.9900	3
105	2	1.1138	-16.0580	-1.9409	2
106	2	0.7503	6.6154	-1.1709	2
107	1	1.0441	21.3850	0.9900	3
108	1	0.8602	5.4114	0.9900	3
109	2	0.9745	-15.4088	-2.6309	2
110	1	1.0164	-2.0314	1.5750	3
111	1	1.0748	-4.9997	0.9900	3
112	2	0.9727	3.8302	-0.9943	2
113	2	1.1576	4.1204	-6.9009	2
114	1	0.9519	4.0549	0.4950	3
115	1	1.0328	-3.6378	0.9900	3

Table C.4: The line parameters of the North Local Power Grid of Shanxi Province

Source Node	Sink Node	Branch Reactance
1	104	0.0622
1	109	0.0748
1	111	0.0504
2	112	0.0662
3	112	0.0035
4	5	0.0322
4	7	0.0244
4	59	0.0030
5	7	0.0161
5	105	0.0480
6	113	0.0048
8	44	0.3945
8	53	0.1660
8	74	1.0158
8	83	0.1534

Source Node	Sink Node	Branch Reactance
8	87	0.1127
9	14	0.0050
9	18	0.0032
9	20	0.0059
9	52	0.0830
9	59	0.0176
9	61	0.0145
9	62	0.0505
9	82	0.0302
10	11	0.6106
10	27	1.0279
10	30	0.1538
10	46	0.2120
10	68	0.1559
11	27	0.2406
11	30	0.0803
11	46	0.0496
11	72	0.0099
11	79	0.0154
12	17	0.0449
12	39	0.0160
13	74	0.1819
13	86	0.0314
13	109	0.0526
15	32	0.0409
15	65	0.6658
15	66	0.0517
15	69	0.1042
15	88	0.0040
16	41	0.0295
16	52	0.1940
16	67	0.0483
17	39	0.0656
17	40	0.0431
17	47	0.0115
17	57	0.0431
18	65	0.0865
18	69	0.1681

Source Node	Sink Node	Branch Reactance
19	31	0.2210
19	86	0.0539
21	34	0.0014
21	48	0.0197
21	68	0.0208
21	113	0.0156
22	58	0.0177
23	67	0.0078
24	65	0.0064
25	50	0.0023
26	44	0.0647
27	30	0.6714
27	46	0.0835
27	68	0.0630
28	30	0.0088
28	76	0.0083
28	85	0.0071
29	30	0.0500
30	46	0.1385
30	50	0.0428
30	59	0.1369
30	67	0.0293
31	75	0.0061
31	81	0.0317
31	86	2.2736
31	109	0.0263
32	55	0.0638
33	41	0.0005
35	50	0.0004
36	69	0.0107
37	65	0.0008
38	42	0.0010
39	54	0.0171
39	80	0.0271
40	57	0.0442
40	60	0.0105
40	62	0.0182
41	48	0.0650

Source Node	Sink Node	Branch Reactance
42	51	0.0257
42	78	0.0071
43	51	0.0050
43	74	0.0855
44	74	0.0768
44	83	2.0159
44	87	0.1698
45	49	0.0200
45	54	0.0399
48	64	0.0058
48	74	0.1036
48	113	0.0364
50	82	0.0293
51	68	0.0201
51	71	0.0053
51	74	0.0796
52	59	0.0374
52	61	0.0696
52	67	0.0483
52	73	0.0706
52	77	0.0055
53	70	0.0568
54	69	0.0371
55	73	0.0569
56	58	0.1162
56	81	0.1376
56	109	0.0979
58	68	0.0936
59	67	0.0516
60	62	0.0293
60	89	0.0061
62	82	0.0290
62	84	0.0004
63	107	0.0384
63	109	0.0022
65	66	0.0713
65	69	0.7989

Source Node	Sink Node	Branch Reactance
66	69	0.0621
8	113	0.0428
74	83	5.1912
74	87	0.4373
81	109	0.0263
83	87	0.5760
90	105	0.0196
91	102	0.0044
92	97	0.0237
93	96	0.0089
94	96	0.0141
95	96	0.0283
96	101	0.0089
96	115	0.0089
97	98	0.0500
97	100	0.0889
98	99	0.0433
100	109	0.0320
100	114	0.0592
102	103	0.0500
103	106	0.0065
105	106	0.0500
108	109	0.1189
109	110	0.0141
112	113	0.0500
114	115	0.0500